



Domestic Consumer Units (18 Edition)

PME Fault detection - Type A RCBO - Load Management



Technical data G10EV40PME DLM

Rated current	40A
Rated voltage	230 V AC
Frequency	50/60 Hz
Rated Conditional Short Circuit (Icc)	Annex ZB: 16kA rms at 250V
Main Device	40A RCBO Type A
Additional Devices	PME Fault detection & D L M
Operation	207V - 253V (4 seconds)
Degree of protection	IP40
Total number of ways	10
Total Number of free ways	1
Height..mm (H)	235
Width..mm (W)	233
Depth..mm (D)	110
Ambient temperature (C)	-25.....+55
Storage temperature (C)	-35.....+55
Terminals	25mm
Material	Metal
Standard	EN 61439-3
	Compliance with BS 7671
Warranty (Mechanical Components)	5 Years
Warranty (Electronic Components)	2 Years
Load Management Current	10 - 110 Amps




Relay settings

Voltage relay: 1 OFF, 2 OFF, 3 ON, 4 OFF.

Current Relay: 1 OFF, 2 ON, 3 OFF, 4 ON, 5 ON, 6 ON.

HYS 0
LEVEL Set to Max current Level 10 -100 Amps
DELAY 30secs

For EV chargers without PME fault detection



1

2

3

4

5

6


7

8

IET BS:7671:2018


722.411.4 TN system (Amendment 1:2020)

(iv) Protection against electric shock in a single-phase installation is provided by a device which electrically disconnects the vehicle from the live conductors of the supply and from protective earth in accordance with Regulation 543.3.3.101(ii) within 5 s in the event of the utilisation voltage at the charging point, between the line and neutral conductors, being greater than 253 V rms or less than 207 V rms. The device shall provide isolation and be selected in accordance with Table 537.4. Equivalent means of functionality could be included within the charging equipment. Closing or resetting of the device shall be possible only if the voltage between line and neutral conductors is in the range 207 to 253 V rms.



NOTE:
INCOMING (RCBO)
TERMINAL 4: PHASE
TERMINAL 2: NEUTRAL
EARTH BAR: EARTH


OUTGOING (CONTACTOR)
TERMINAL 1: EARTH
TERMINAL 3: PHASE
TERMINAL 5: NEUTRAL



233mm

235mm

110mm



G10EV40PMELM
(METAL IP41)

NO	DESCRIPTION	DATE	NAME	CHECK	APPD

PROJECT

MCU 40A Type B RCBO, PME Fault Detection
& Load Management

DRAWING No.

G10EV40PMELM

PROJECT No

SHEET

1 -

GARO



Dokument/document Försäkran om överensstämmelse/ Declaration of conformity		Utgava datum/edition date 2018-06-14
Avdelning/department Kvalite/Quality		
Ansvarig/prepared Magnus Arvidsson	Version 3	Sida/page 1 av/of 1

Supplier/Tillverkare:

GARO AB
Box 203
S-335 25 GNOSJO
Sweden

Telephone: +46 (0)370 33 28 00

Telefax: +46 (0)370 33 28 50

Supplier established within EU/Ombud etablerad inom EG

Supplier of equipment /Materielslag : Consumer unit/Normcentral

Trade Mark/ Varumärke: GARO

Type Designation / Typbeteckning: G, GS, 4, 6, 8, 10, 12, 14,16,18, 21, 28, 32, EV, S, R,
C, PME, B , M, DLM

We hereby declare that our product fulfils the requirements of following EC directives/
Vi intygar härmed att vår produkt uppfyller krav enligt följande EU direktiv:

- ☒ The Low Voltage Directive (LVD) 2014/35/EU / Lågspänningsdirektivet (LVD) 2014/35/EU.
- ☐ Electromagnetic compatibility (EMC) 2004/108/EU / Elektromagnetisk kompatibilitet (EMC) 2004/ 108/EG.
- ☒ RoHS Directive (RoHS) 2011/65/EU / RoHS direktivet (RoHS) 2011/65/EG.
- ☒ No electromagnetic compatibility (EMC) immunity or emission tests are required on the assembly/
Produkten innehåller inte elektroniska apparater som påverkas enligt förbehållen enligt direktivet
(EMC) 2004/108/EG.

The following harmonised standards (latest edition) or technical specifications which comply with good engineering practice in safety matters in force within the EU have been used in the design: /

Följande harmoniserade standarder (senaste utgåva) eller tekniska specifikationer som uppfyller god säkerhetsteknik praxis inom EG har använts i konstruktionen: SS EN 61439-3

- ☒ The equipment conforms completely with the above stated harmonised standards or technical specifications. /
Materielen överensstämmer helt med ovan angivna harmoniserade standarder eller tekniska specifikationer.

Or/eller

- ☐ The equipment confirms only partially with the above stated harmonised standards or technical specifications but complies with good practice in safety matters in force within the EU. /
Materielen överensstämmer endast delvis med ovan angivna harmoniserade standarder eller tekniska specifikationer, men uppfyller god säkerhetsteknik praxis inom EG.

We have product surveillance according to CENELEC's harmonised requirements, documents CCA-201.

Garo AB
Company/Företag

2018-06-14
Date/Datum

Sign/Underskrift

Environmental- and Quality Manager/Kvalitets- och Miljöchef
Position/Befattning

Magnus Arvidsson
Name / Namnförtydligande